

General Environmental Incident Summary

Incident: 2119 **Date/Time Notice:** 11/22/2013 1145 **DEM Incident No:**
Responsible Party: John E. Haggart Trust c/o Wells Fargo Trust
Date Incident: 11/22/2013 **Time Incident:** 1130 **Duration:** 10 minutes
County: Cass **Twp:** 139 **Rng:** 49 **Sec:** 1 **Qtr:** NE SW
Lat: 46.88235 **Long:** -96.80942 **Method:** Interpolation from map
Location Description: 1802 7th Avenue N
Fargo, ND 58102

Submitted By: David Schultz **Affiliation:** Vieau Associates
Address: 7710 Computer Ave
Suite 102
City: Edina **State:** MN **Zip:** 55435

Received By:

Contact Person: Andrew Heinrich
PO Box 340
730 Center Ave
Moorhead , MN 56560

Distance Nearest Occupied Building: 50 Feet

Type of Incident: Tank Leak

Description of Released Contaminant: Diesel Fuel

Volume Spilled: 5.00 gallons **Ag Related:** No

EPA Extremely Hazardous Substance: No **Reported to NRC:** No

Cause of Incident:

Spill or overfill of former diesel fuel UST

Risk Evaluation:

No immediate risks identified

of Fatalities: 0 **# of Injuries:** 0 **Affected Medium:** 02 - water

Potential Environmental Impacts:

Low level impacts to groundwater were identified in a November 21, 2013 Phase II investigation. The highest level of DRO detected in groundwater was 744 ppb. No DRO or VOCs were detected in soil.

Action Taken or Planned:

Two diesel fuel USTs were removed in 1984

Wastes Disposal Location: N/A

Agencies Involved:

Updates

Date: 11/22/2013 ***Status:*** Reviewed - Assigned to NDDoH Division

Author: Mittelsteadt, Mark

Updated Volume:

Notes:

Forwarded the report to Waste Management, UST Program and Fargo Field Office for follow-up.